

ITEM C203.0951 #1 CRUSHED STONE BEDDING

DESCRIPTION

This work shall consist of furnishing, placing, and compacting crushed stone bedding for sewer pipes as shown on the plans or as directed by the ENGINEER.

MATERIALS

The materials shall meet the requirements of NYSDOT Standard Specifications, Subsection 703-02, Material Designation 703-0201, latest revision, and shall be furnished in the sizes or combination of sizes indicated on the plans or ordered by the ENGINEER.

CONSTRUCTION DETAILS

The construction details of NYSDOT Standard Specifications, Subsection 203-3, latest revision, shall apply except for the following modifications:

When crushed stone is used for pipe bedding, it shall be placed, compacted, and shaped to fit the lower half of the pipe to the dimensions shown on the plans. Crushed stone shall be deposited in horizontal layers not exceeding 6 inches in thickness prior to compaction.

METHOD OF MEASUREMENT

The method of measurement of NYSDOT Standard Specifications, Subsection 203-4, latest revision, shall apply except for the following modifications:

The quantity of crushed stone to be paid for shall be the number of cubic yards computed in the final compacted position within the payment lines shown on the plans or as ordered by the ENGINEER.

BASIS OF PAYMENT

Payment will be made under:

<u>Item No.</u>	<u>Item</u>	<u>Pay Unit</u>
C203.0951	#1 Crushed Stone Bedding	CY